

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 68099
 Permit No. _____
 Basin 71

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26875

1. OWNER E. W. Westmoreland ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 2550 S. Grass Valley Rd. Winnemucca, NV 89445
Winnemucca, NV 89446

2. LOCATION NE 1/4 SE 1/4 Sec. 24 T 35N N/S R 37E E Humboldt County
 PERMIT NO. _____ D-1
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	5	5
Sand & gravel		5	32	27
Gravel some clay		32	140	108
Perf		60	100	

Fill with hole plug to 60' topped with 6 sacks grout.

ABANDONMENT

Plugging of well log # 44725

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.81	3/16	0	140

Perforations:
 Type perforation Mill slot
 Size perforation 1/8
 From 100 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 84 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 5/27/94, 19
 Date completed 5/27/94, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift Draw Down (Feet Below Static)	<u>25</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc.
 Contractor
 Address 4675 W. Winnemucca Blvd
 Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 6-24-97