WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68099
Permit No.
Basin 71

NOTICE OF INTENT NO. 36918

1. OWNER Keith and Carol Pilikian
MAILING ADDRESS P. O. Box 3521
Winnemucca, NV 89446

ADDRESS AT WELL LOCATION Lot 23 BLK A
5865 Wren

2. LOCATION ____ 1/4 W1/2 1/4 Sec. 7 T 34N N/S R 38E E Pershing County
PERMIT NO. ____ Issued by Water Resources | 09-412-09 Parcel No. | Burns Acres unit #3 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay		0	53	53
Gravel		53	68	15
Clay w/sand & gravel layers	x	68	115	47

RECEIVED
97 JUL 14 AM 11:45
STATE ENGINEER'S OFFICE

Date started 6/30/97, 19__
Date completed 7/1/97, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 115 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 7/8	Inches	0 Feet	115 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	110

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 x 3
From 90 feet to 110 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 110 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 7-1-97