

OFFICE USE ONLY
 Log No. 68103
 Permit No. _____
 Basin 071

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28379

1. OWNER Rich Brown ADDRESS AT WELL LOCATION 4690 Brayton Rd.
 MAILING ADDRESS 3565 Brown Ln. Winnemucca, NV 89445
 2. LOCATION SW $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 7 T. 35 N/S R. 38 E. Humboldt County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	7	7
Gravel		7	18	11
Clay w/gravel & Cobbles		18	90	72
Rock w/ clay filled fractures		90	130	40
Clay		130	145	15
Rock w/ clay filled fractures		145	190	55
Rock w/ sand & gravel filled fractures		190	227	37

8. WELL CONSTRUCTION
 Depth Drilled 227 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 227 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>220</u>

Perforations:
 Type perforation mill slot
 Size perforation 1/8"
 From 180 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 227 feet

9. WATER LEVEL
 Static water level 160 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

Date started 8-9, 1996
 Date completed 8-12, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>		<u>3 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co. Inc. Contractor
 Address 4675 W. Winnemucca Blvd. Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8-26-96