WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68104
Permit No.
Basin 44

NOTICE OF INTENT NO. 36873

1. OWNER REX & KIM LISH
MAILING ADDRESS P.O. BOX 1461
ELKO, NV 89803

ADDRESS AT WELL LOCATION
NO. SIDE OF SO. 6TH ST BETWEEN VANBUREN & JACKSON

2. LOCATION SE 1/4 SW 1/4 Sec. 5 T 35N N/S R 57E E ELKO County
PERMIT NO. (Issued by Water Resources) Parcel No. 26-027-006 Subdivision Name TRR #4

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOPSOIL | | 0 | 2 | 2 |
| SAND & GRAVEL | | 2 | 8 | 6 |
| SILTSTONE & BOULDERS | X | 8 | 120 | 112 |

Date started 7/31/97, 19__
Date completed 7/31/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 45 | | 2 |

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 5/8 | Inches | 0 Feet | 120 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | .188 | +1 | 120 |

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed David Nelson (By driller performing actual drilling on-site or contractor)
Date 8-1-97

RECEIVED 97 AUG 25 AM 10:20