

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36606

1. OWNER DEW INC ADDRESS AT WELL LOCATION LA VISTA DR and ARTHUR AVE Lot 1  
 MAILING ADDRESS PO Box 311 ELKO NV 89803  
 2. LOCATION SW 1/4 NW 1/4 Sec. 36 T. 36 N. R. 56 E ELKO County  
 PERMIT NO. 006-33H-061 Parcel No. \_\_\_\_\_ Subdivision Name Rynden

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY loam		0	12	12
Hard PAN		12	20	8
CLAY		20	91	71
SANDSTONE		91	150	59
SOFT SANDSTONE	X	150	172	22

8. WELL CONSTRUCTION  
 Depth Drilled 172 Feet Depth Cased 172 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 172 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>1.88</u>	<u>±2</u>	<u>172</u>

Perforations:  
 Type perforation Mill slots  
 Size perforation 3/16 x 3"  
 From 152 feet to 172 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 54'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 54 feet to 172 feet

9. WATER LEVEL  
 Static water level 103 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

Date started 8-15, 1997  
 Date completed 8-15, 1997

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>APORX</u>	<u>30</u>	<u>NA</u>	<u>2.5</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FERTIG Drilling Co Contractor  
 Address PO Box 525 Contractor  
ELKO NV 89803  
 Nevada contractor's license number issued by the State Contractor's Board 0031904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Shane C. Fertig  
 By driller performing actual drilling on site or contractor  
 Date 9-1-97