WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68110
Permit No.
Basin 071

NOTICE OF INTENT NO. 28363

1. OWNER Brown- Davy Rd. Lot #17
MAILING ADDRESS 3565 Brown Ln.
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 6175 ~~Davy Rd.~~ DAVEY RD
Winnemucca, NV 89445

2. LOCATION SW ¼ SE ¼ Sec. 7 T 35 N S R 38 E Humboldt County

PERMIT NO. (Issued by Water Resources) | 10-482-17 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Sandy Clay		0	9	9
Gravel & Cobbles		9	21	12
Clay w/ gravel		21	147	106
Cobbles & boulders				
Clay		147	162	25
Rock w/sand & gravel		162	208	46
fractures				

RECEIVED 96 AUG 30 AM 11:21 STATE ENGINEER'S OFFICE

Date started 8-24, 19 96
Date completed 8-25, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		3 1/2

8. WELL CONSTRUCTION
Depth Drilled 208 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	208 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	200

Perforations:
Type perforation Mill slot
Size perforation 178
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 208 feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co. Inc. (Contractor)
Address 4675 W. Winnemucca Blvd. (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-29-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627