WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68116
Permit No.
Basin 071

NOTICE OF INTENT NO. 28377

1. OWNER Rich Brown
MAILING ADDRESS 3565 Brown Ln.
Winnemucca NV 89445

ADDRESS AT WELL LOCATION Brayton Rd/Lariat Ct.
Winnemucca, NV 89445

2. LOCATION SW ¼ SE ¼ Sec. 7 T 35 (N)S R 38 E Humboldt County
PERMIT NO. Issued by Water Resources | Parcel No. 10-482-22 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand & Sandy clay | | 0 | 6 | 6 |
| Gravel | | 6 | 14 | 8 |
| Clay w/gravel | | 14 | 102 | 88 |
| & Cobbles | | | | |
| Lost Circulation | | 102 | 127 | 25 |
| Rock w/clay | | 127 | 163 | 36 |
| filled fractures | | | | |
| Rock w/sand & | | 163 | 200 | 37 |
| gravel filled frac. | | | | |

Date started 8-12, 1996
Date completed 8-16, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 15 | | |

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 195 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 9 7/8 Inches | | 0 Feet | 180 Feet |
| 6 1/8 Inches | | 180 Feet | 200 Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | 1/4 | +1 | 180 |
| 5 9/16 | | 1/4 | 180 | 195 |

Perforations:
Type perforation Mill slot
Size perforation 1/8 x 3
From 165 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 56
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 160 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co. Inc. (Contractor)
Address 4675 W. Winnemucca Blvd. (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed [signature]
By driller performing actual drilling on site or contractor
Date 8/22/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627