WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68146
Permit No.
Basin 649
I

NOTICE OF INTENT NO. 30577

1. OWNER Craig Siri
MAILING ADDRESS HC-30 Box 6
Elko, NV 89801

ADDRESS AT WELL LOCATION N. Side of 28th St. between Osage & Crow Ave.

2. LOCATION NE ¼ NW ¼ Sec. 19 T 35 N/S R 56 E Elko County
PERMIT NO. (Issued by Water Resources) 36-002-06 (Parcel No.) MVR #4 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2'
Boulders & Gravel		2	18	16'
Brown Siltstone	X	18	158	140'
& Pea Gravel				
Medium Gravel	X	158	175	17'
Clay		175	180	5'
Medium Gravel	X	180	200	20'

Date started 3-19, 19 96
Date completed 3-20, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow Test	20		2-1/2

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches		0 Feet	50 Feet
9-7/8 Inches		50 Feet	200 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1-1/2	200

Perforations:
Type perforation Millslot
Size perforation 3/16 x 3"
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 62 feet below land surface
Artesian flow --- G.P.M. --- P.S.I.
Water temperature Cold °F Quality ---

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed John C. Siri (By driller performing actual drilling on site or contractor)
Date 3-26-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627