


OFFICE USE ONLY  
 Log No. 68149  
 Permit No. \_\_\_\_\_  
 Basin. 049



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30700

1. OWNER JOAQUIN RAMIREZ ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1400 MTC Highway BULLION Rd x A STREET  
Elko NV 87801 Elko NV  
 2. LOCATION NW 1/4 NW 1/4 Sec 28 T 34 N/S R 55 E Elko County  
 PERMIT NO. 06-094-86-7 West Bullion Subdivision Name  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other M&D

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Loam</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Red Clay</u>		<u>2</u>	<u>12</u>	<u>10</u>
<u>Gravel</u>	<u>X</u>	<u>12</u>	<u>35</u>	<u>23</u>
<u>Red Clay</u>		<u>35</u>	<u>57</u>	<u>22</u>
<u>Build Clay</u>		<u>57</u>	<u>59</u>	<u>2</u>
<u>Cemented Gravel</u>		<u>59</u>	<u>87</u>	<u>28</u>
<u>Red Clay</u>		<u>87</u>	<u>113</u>	<u>26</u>
<u>Sand Gravel</u>	<u>X</u>	<u>113</u>	<u>152</u>	<u>39</u>

8. WELL CONSTRUCTION  
 Depth Drilled 152 Feet Depth Cased 152 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 Inches 0 Feet 152 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>1.88</u>	<u>71.6</u>	<u>152</u>

Perforations:  
 Type perforation slots  
 Size perforation 3/16" x 3"  
 From 132 feet to 152 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 152 feet

9. WATER LEVEL  
 Static water level 13' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fentig Drilling Co Contractor  
 Address 70 Box 525 Contractor  
Elko NV 87801  
 Nevada contractor's license number issued by the State Contractor's Board 0031904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Stacy J. Fentig  
 By driller performing actual drilling on site or contractor  
 Date 4-16-86

Date started 4-2, 1986  
 Date completed 4-4, 1986

7. WELL TEST DATA

	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Apex</u>	<u>50</u>		<u>35</u>