


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15340

1. OWNER: South Valley Baptist Church ADDRESS AT WELL LOCATION: LOT 5
MAILING ADDRESS: _____

2. LOCATION: NE 1/4 NE 1/4 Sec 24 T. 21S N/S R 53E E Nye County
PERMIT NO. 62552 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED: New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE: Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE: Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown Clay</u>		<u>0</u>	<u>15</u>	<u>15</u>
<u>Caliche</u>		<u>15</u>	<u>18</u>	<u>3</u>
<u>Brown Clay</u>		<u>18</u>	<u>52</u>	<u>34</u>
<u>Grey Clay</u>	<u>X</u>	<u>52</u>	<u>106</u>	<u>54</u>
<u>Caliche</u>	<u>X</u>	<u>106</u>	<u>109</u>	<u>3</u>
<u>Grey clay</u>	<u>X</u>	<u>109</u>	<u>140</u>	<u>31</u>

8. WELL CONSTRUCTION
Depth Drilled: 140 Feet Depth Cased: 140 Feet
HOLE DIAMETER (BIT SIZE)
From 12 Inches To 0 Feet 140 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>		<u>Sch. 80 PVC</u>	<u>0</u>	<u>140</u>

Perforations:
Type perforation: Saw
Size perforation: 3 1/2 x 5
From _____ feet to _____ feet
From 110 feet to 130 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal: 50
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level: 53 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature: Cold °F Quality: Good

Date started: 8-8, 1997
Date completed: 8-11, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>7</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: Larry Water Well Service Contractor
Address: P.O. Box 3392 Contractor
Pahrump, NV 89001
Nevada contractor's license number issued by the State Contractor's Board: 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1916
Signed: Larry Jenkins
By driller performing actual drilling on site or contractor
Date: _____