WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68174
Permit No.
Basin 212

NOTICE OF INTENT NO. 17352

1. OWNER City of Las Vegas - Economic & Urban Dev.
MAILING ADDRESS 400 S. Las Vegas Blvd
Las Vegas NV 89101
ADDRESS AT WELL LOCATION 401 S. Las Vegas Blvd
Las Vegas NV

2. LOCATION NW ¼ SE ¼ Sec. 34 T. 20 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 139-34-701-001 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill | | 0 | 1 | 1 |
| Sandy Silt (Fill) | | 1 | 5 | 4 |
| Silty Clay (Fill) | | 5 | 15 | 10 |
| Sandy Clay | | 15 | 20 | 5 |

Date started Aug 5, 1997
Date completed Aug 5, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 8 Inches | 0 Feet | 20 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.375 | 0.64 | 0.154 | 0 | 20 |
| | | | | |

Perforations:
Type perforation Factory Slot
Size perforation 0.020
From 10 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-1' / 1-3' Bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 20 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thomas High (Converse Cons.) Contractor
Address 731 Pilot Rd Ste H Contractor
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 0034757
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed By driller performing actual drilling on site or contractor
Date 10/1/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627