WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68184
Permit No.
Basin 59

NOTICE OF INTENT NO. 38527

1. OWNER Dave Itza
MAILING ADDRESS 255 E. 2nd. St.
Battle Mountain, NV 89820

ADDRESS AT WELL LOCATION
Corner of James Madison & 1500 E. Street

2. LOCATION 1/4 SE 1/4 Sec. 32 T 32N N/S R 45E E Lander County
PERMIT NO. Issued by Water Resources | Parcel No. 011-210-28 | Subdivision Name

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay | | 0 | 5 | 5 |
| Gravel & cobbles | | 5 | 26 | 21 |
| Gray clay | | 26 | 83 | 57 |
| Sand & gravel | x | 83 | 105 | 22 |

Date started 8/23/97, 19__
Date completed 8/24/97, 19__

**7. WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 35 | | 4 hrs. |

**8. WELL CONSTRUCTION**
Depth Drilled 105 Feet Depth Cased 100 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | To |
|---|---|---|---|
| 10 7/8 | Inches | 0 Feet | 105 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | +1 | 100 |

**Perforations:**
Type perforation Mill slot
Size perforation 1/8 x 3
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 100 feet

**9. WATER LEVEL**
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 W. Winnemucca Blvd
Contractor
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed [signature]
By driller performing actual drilling on-site or contractor
Date 8-26-97