



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37101

1. OWNER Norman J. & Alethead Clark ADDRESS AT WELL LOCATION Block 11 Lot - 5  
 MAILING ADDRESS Meadow Valley Ranches #4 295-13 ELKO NV

2. LOCATION SW 1/4 SW 1/4 Sec. 19 T. 35 S. R. 56 E. ELKO County \_\_\_\_\_  
 PERMIT NO. 36-011-05-4 Issued by Water Resources Parcel No. \_\_\_\_\_  
Meadow Valley Ranches Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Caliche		2	5	3
Cemented Gravel		5	32	27
Clay		32	58	26
Cemented Gravel		58	172	114
gravel sand	X	172	198	26
Cemented Gravel		198	238	40
gravel sand	X	238	268	30
Cemented Gravel		268	275	7

8. WELL CONSTRUCTION

Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 275 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>275</u>

Perforations:  
 Type perforation pac  
 Size perforation \_\_\_\_\_  
 From 225 feet to 265 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 275 feet

Date started June 5, 1996  
 Date completed June 5, 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>307</u>	<u>0</u>	<u>2</u>

9. WATER LEVEL  
 Static water level 143 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AAA Drilling Contractor  
 Address P.O. Box 247 Contractor  
ELKO NV  
 Nevada contractor's license number issued by the State Contractor's Board 0020684  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438  
 Signed Shane Bennett  
 By driller performing actual drilling on site or contractor  
 Date June - 05 96