

OFFICE USE ONLY
 Log No. 68220
 Permit No. _____
 Basin. 071
 NOTICE OF INTENT NO. 30414

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Cliff Burns ADDRESS AT WELL LOCATION 205 WREN ST. Block A Lot 18
 MAILING ADDRESS 2008 3RD ST. Sparks, NV 89431
 2. LOCATION NW 1/4 NW 1/4 Sec. 7 T. 34 S. R. 38 E. Pershing County
 PERMIT NO. 9-421-15 Parcel No. BURNS Aches Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay/SAND		0	20	20
SAND/gravel		20	30	10
Encased Layers		30	60	30
SAND/gravel		60	80	20
SAND/gravel		80	90	10
SAND/gravel	XX	90	110	20

8. WELL CONSTRUCTION
 Depth Drilled 110 Feet Depth Cased 110 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 110 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>12</u>	<u>188</u>	<u>1</u>	<u>110</u>

Perforations:
 Type perforation Factory Cuts
 Size perforation 3/32
 From 90 feet to 110 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 110 feet

9. WATER LEVEL
 Static water level 67 feet below land surface
 Artesian flow NO G.P.M. N/A P.S.I.
 Water temperature COOL °F Quality GOOD

Date started 2-18 1996
 Date completed 2-18 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20</u>	<u>N/A</u>	<u>2 hr.</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FRED ANDERSON Contractor
 Address 10760 Grass Valley Rd. Winnemucca, NV 89445 Contractor
 Nevada contractor's license number 0021467 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources 1375 the on-site driller.
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 4/26/96