

OFFICE USE ONLY
 Log No. 68224
 Permit No. 071
 Basin. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30436

1. OWNER Cliff Buens ADDRESS AT WELL LOCATION Lot 6 Blk B - JDS HAWK
 MAILING ADDRESS 2008 3rd St. Sparks, NV 89431
 2. LOCATION NW 1/4 NW 1/4 Sec. 7 T. 34 N. R. 38 E. DERSHING County
 PERMIT NO. _____ Subdivision Name BUENS ACRES

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay / SAND		0	20	20
SAND / GRAVEL		20	30	10
Fingered Layers		30	60	30
SAND / GRAVEL		60	80	20
SAND / GRAVEL		80	90	10
SAND / GRAVEL	XX	90	110	20

8. WELL CONSTRUCTION
 Depth Drilled 110 Feet Depth Cased 110 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 110 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>12</u>	<u>1.88</u>	<u>1</u>	<u>110</u>

Perforations:
 Type perforation Factory Cuts
 Size perforation 3/32
 From 90 feet to 110 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 110 feet

9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow NO G.P.M. N/A P.S.I.
 Water temperature 60.1 °F Quality Good

Date started 5/14, 1996
 Date completed 5/14, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>N/A</u>	<u>2 hr</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson Contractor
 Address 10760 Grass Valley Winnemucca, NV 89445 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 21467
 Nevada driller's license number issued by the Division of Water Resources 1375
 Signed _____ By driller performing actual drilling on site or contractor
 Date 6/3/96