

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30432

1. OWNER Cliff Burns ADDRESS AT WELL LOCATION Lot # 4 Blk C - 230 Hawk  
 MAILING ADDRESS 2008 3rd St. Sparks, NV 89431  
 2. LOCATION NW 1/4 NW 1/4 Sec 7 T 34 R 38 E Pershing County  
 PERMIT NO. 9-411-04 Parcel No. Burns Acres Subdivision Name

3. WORK PERFORMED  
 New Well     Replace     Recondition  
 Deepen     Abandon     Other  
 4. PROPOSED USE  
 Domestic     Irrigation     Test  
 Municipal/Industrial     Monitor     Stock  
 5. WELL TYPE  
 Cable     Rotary     RVC  
 Air     Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY/SAND		0	20	20
SAND/GRAVEL		20	30	10
Fingered Layers		30	60	30
SAND/GRAVEL		60	80	20
SAND/GRAVEL		80	90	10
SAND/GRAVEL	X	90	110	20

8. WELL CONSTRUCTION  
 Depth Drilled 110 Feet    Depth Cased 110 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 7/8 Inches    To 110 Feet  
 \_\_\_\_\_ Inches    \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches    \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 7/8</u>	<u>12</u>	<u>1.88</u>	<u>1</u>	<u>110</u>

Perforations: Factory Cuts  
 Type perforation  
 Size perforation 3/32  
 From 90 feet to 110 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes     No    Seal Type:  Neat Cement  
 Depth of Seal 50     Cement Grout  
 Placement Method:  Pumped     Concrete Grout  
 Poured  
 Gravel Packed:  Yes     No  
 From 50 feet to 110 feet

9. WATER LEVEL  
 Static water level 63 feet below land surface  
 Artesian flow ND G.P.M. N/A P.S.I.  
 Water temperature 62.1 °F    Quality Good

Date started 5/17 1996  
 Date completed 5/17 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>N/A</u>	<u>2 hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FRED ANDERSON Contractor  
 Address 10760 Grass Valley Winnemucca, NV 89445  
 Nevada contractor's license number issued by the State Contractor's Board 21467  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1375  
 Signed \_\_\_\_\_  
 Date 5/13/96