


OFFICE USE ONLY  
 Log No. 68228  
 Permit No. \_\_\_\_\_  
 Basin. 071   
 NOTICE OF INTENT NO. 30434

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Cliff Burns ADDRESS AT WELL LOCATION Lot 4 BLKD - 5820 LAGLE  
 MAILING ADDRESS 2008 3RD ST. Sparks NV 89131  
 2. LOCATION SW 1/4 NW 1/4 Sec. 7 T. 34 S. R. 38 E Pershing County  
 PERMIT NO. 9-431-04 BURNS ACRES Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY / SAND		0	20	20
SAND / gravel		20	30	10
fingered Lenses		30	60	30
SAND / gravel		60	80	20
SAND / gravel		80	90	10
SAND / gravel	XX	90	110	20

8. WELL CONSTRUCTION  
 Depth Drilled 110 Feet Depth Cased 110 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 110 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>1.88</u>	<u>1</u>	<u>110</u>

Perforations:  
 Type perforation Factory Cuts  
 Size perforation 3/32  
 From 90 feet to 110 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 110 feet

9. WATER LEVEL  
 Static water level 6.6 feet below land surface  
 Artesian flow NO G.P.M. N/A P.S.I.  
 Water temperature 60.1 °F Quality Good

Date started 5/22, 1996  
 Date completed 5/22, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>N/A</u>	<u>2 hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fred Anderson Contractor  
 Address 10760 Grass Valley Winnemucca, NV 89445 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board: 21467  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1375  
 Signed \_\_\_\_\_  
 Date 6/4/96  
 By driller performing actual drilling on site or contractor