WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 68238
Permit No.
Basin 059

NOTICE OF INTENT NO. 35021

1. OWNER Wes Bennett
MAILING ADDRESS 32574 Ave. D.
Yucaipa, CA 92399

ADDRESS AT WELL LOCATION Unionville Highway

2. LOCATION NE 1/4 NE 1/4 Sec. 8 T 31N N/S R 35 E Pershing County
PERMIT NO. _____ Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay w/gravel		0	83	83
See next line		83	370	287
Fractured rock w/clay & gravel				
Fractured rock w/sand		370	400	30
Fractured rock w/clay		400	420	20

Date started 3/14/97, 19__
Date completed 3/23/97, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
6 - 7		3

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 7/8	Inches	0	Feet	420	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	400

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 X 3
From 375 feet to 400 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured

Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 325 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed [signature] (By driller performing actual drilling on-site or contractor)

Date 4-3-97