



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Steve Bickford ADDRESS AT WELL LOCATION Box 5044 2150 NJ
 MAILING ADDRESS Box 5044 2150 NJ ADDRESS Park St HHA #1 Ryndon NJ
 2. LOCATION NE 1/4 SE 1/4 Sec 31 T. 36 N. S. R. 57 E. EIKO County EIKO
 PERMIT NO. HHR # 1 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	4	4
Clay sand		4	80	76
clay		80	174	94
Gravel sand	X	174	215	41
Clay		215	225	10

8. WELL CONSTRUCTION
 Depth Drilled 225 Feet Depth Cased 225 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 225 Feet
Inches.....Feet.....Feet
Inches.....Feet.....Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>225</u>

Perforations:
 Type perforation Fac
 Size perforation
 From 190 feet to 210 feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 225 feet

9. WATER LEVEL
 Static water level 88 feet below land surface
 Artesian flow.....G.P.M.....P.S.I.
 Water temperature.....°F Quality.....

Date started August 15, 1997
 Date completed August 15, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>207</u>	<u>80</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Steve Well Service Contractor
 Address P.O. Box 10 Contractor
EIKO NJ
 Nevada contractor's license number issued by the State Contractor's Board 0038169
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438
 Signed Alan Bennett
 By driller performing actual drilling on site or contractor
 Date August 15-97