

Log No. 68255
 Permit No. 044
 Basin

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35953

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Gary Cummings ADDRESS AT WELL LOCATION Bik 28-dot 6
 MAILING ADDRESS P.O. Box 388 MUR #1
EIKO NV 89803

2. LOCATION NW 1/4 NE 1/4 Sec. 1 T 35 N/S R 56 E EIKO County
 PERMIT NO. 30-028-06-2 Ryndon Subdivision Name

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------|--------------|------|-----|------------|
| Loam | | 0 | 2 | 2 |
| Hard PAN | | 2 | 10 | 8 |
| Gravel | | 10 | 15 | 5 |
| CLAY | | 15 | 86 | 71 |
| Gravel | x | 86 | 87 | 1 |
| CLAY | | 87 | 94 | 7 |
| Gravel | x | 94 | 95 | 1 |
| CLAY | | 95 | 109 | 14 |
| SAND & Gravel | x | 109 | 122 | 13 |

PUMP SET @ 110'
 MDC # 7A7B
 SERIAL # 18931-S
 1" PVD 12-3 WIRE
 HAYELL POMP
 SET ON 4-11-97

REC'D
 97 APR 18
 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 122 Feet Depth Cased 122 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 122 Feet
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 3/4</u> | <u>12.92</u> | <u>188</u> | <u>72</u> | <u>120</u> |

Perforations:
 Type perforation mill spots
 Size perforation 3/16 x 3"

From 102 feet to 122 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 59

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 53 feet to 122 feet

9. WATER LEVEL
 Static water level 71' feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature Warm °F Quality

Date started 4-4, 1997
 Date completed 4-8, 1997

7. WELL TEST DATA

| TEST METHOD: | TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | | |
|--------------|---|-------------------------------|--------------|
| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
| <u>APOR</u> | <u>20</u> | | <u>4.5</u> |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Co Contractor
 Address P.O. Box 525 Contractor
EIKO NV 89803

Nevada contractor's license number issued by the State Contractor's Board 6031904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shaul C. Fertig
 By driller performing actual drilling on site or contractor
 Date 4-15-97