



Log No. 68256  
 Permit No. 044  
 Basin 35952

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39952

1. OWNER Gary Cummings ADDRESS AT WELL LOCATION Blk 29 Lot 5  
 MAILING ADDRESS PO Box 358 3RD ST  
Elko NV 89803

2. LOCATION NW 1/4 NE 1/4 Sec. 1 T. 35 S. R. 56 E Elko County  
 PERMIT NO. 30-028-05-4 Parcel No. 1 Subdivision Name MUR #1 RYNDON

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loam		0	2	2
Hard pan		2	13	11
Gravel	X	13	15	2
CLAY		15	89	74
Gravel	X	89	94	9
CLAY		94	119	24
Gravel	X	119	119	1
CLAY		119	122	3
Gravel & SAND	X	122	140	19

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 1/2 Inches To 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>12.92</u>	<u>1/8</u>	<u>+ 2</u>	<u>140</u>

Perforations:  
 Type perforation mill slots  
 Size perforation 3/4" x 3"  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 55'

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 55 feet to 140 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow X 2.5 G.P.M. 2.5 P.S.I.  
 Water temperature 62.0 °F Quality \_\_\_\_\_

Date started 4-13, 1997  
 Date completed 4-16, 1997

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>32</u>	<u>3.2</u>	<u>4.0</u>
<u>Apoka</u>			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Co Contractor  
 Address PO Box 528 Contractor  
Elko NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0031904  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 15841

Signed Shane Fertig  
 By driller performing actual drilling on site or contractor  
 Date 5-9-97