WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.040

OFFICE USE ONLY
Log No. 68257
Permit No.
Basin 72

NOTICE OF INTENT NO. 36940

1. OWNER Jim Fulton
MAILING ADDRESS P.O. Box 333
Imlay, NV 89418

ADDRESS AT WELL LOCATION Lot 3 BLKD
265 State Route 400

2. LOCATION W/2 of SW 1/4 NE 1/4 Sec. 5 T 32N N/S R 35E E Pershing County
PERMIT NO. (Issued by Water Resources) 8-431-03 (Parcel No.) Mill City Acres (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay w/cobbles		0	63	63
Clay		63	150	87
See next line	x	150	300	150
Clay w/small sand & gravel layers				

RECEIVED 97 AUG 14 AM 11:08 STATE ENGINEER'S OFFICE

Date started 7/30/97, 19__
Date completed 8/1/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 290 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 7/8 Inches		0 Feet	200 Feet
6 1/8 Inches		200 Feet	300 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	200
5 9/16		.188	180	290

Perforations:
Type perforation Mill slot
Size perforation 1/8 x 3
From 160 (6 5/8) feet to 200 feet
From 200 (5 9/16) feet to 290 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's licenee number issued by the Division of Water Resources, the on-site driller 1562
Signed Jeri A. Jones (by driller performing actual drilling on-site or contractor)
Date 8-13-97