WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68259
Permit No.
Basin 179

NOTICE OF INTENT NO. 33051

1. OWNER Tom Fruchantie
MAILING ADDRESS P.O. Box 343
Ruth, NV 89319

ADDRESS AT WELL LOCATION 6 miles north of Ely

2. LOCATION NE ¼ SW ¼ Sec. 15 T 17 N/S R 63 E White Pine County
PERMIT NO. 2 of Lot #44 (Issued by Water Resources) 05-58-75 (Parcel No.) Cross Timbers (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Clay & Gravel		5	15	10
Sand & Gravel		15	50	35
Clay & Sand		50	80	30
Water Sand & Gravel	x	80	130	50
Clay & Gravel		130	140	10
Water Sand & Gravel	x	140	145	5
Clay & Gravel		145	160	15

RECEIVED 97 JUL -7 AM 1:44 STATE ENGINEER'S OFFICE

Date started June 26, 1997
Date completed July 2, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
250	84	1

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	160

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	160

Perforations:
Type perforation Factory
Size perforation 1/8 x 2½ 6 rows
From 60 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 66 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
Signed Gerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date July 3, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627