WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 682267
Permit No.
Basin 003

NOTICE OF INTENT NO. 30325

1. OWNER MIDAS JOINT VENTURE
MAILING ADDRESS 6151 LAKESIDE DRIVE
RENO, NV 89511

ADDRESS AT WELL LOCATION NEAR MIDAS NEVADA

2. LOCATION NE 1/4 NW 1/4 Sec. 21 T 39N N/S R 46E E ELKO County
PERMIT NO. 62063T (Issued by Water Resources) TRACT (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BOULDERS & CLAY		0	40	40
GREY/GREEN ROCK W/CLAY	SEAMS	40	70	30
BROWN VOLCANIC ROCK		70	80	10
GREU/GREEN ROCK W/ GREY	CLAY	80	200	120
GREY/GREEN ROCK	X	200	350	150
See next line	X	350	400	30
GREY/GREEN/WHITE ROCK-FRACTURED				

RECEIVED 96 AUG 27 AM 11:38 STATE ENGINEER'S OFFICE

Date started 7/13/96, 19__
Date completed 7/13/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		3

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	400 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	400

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 380 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 8-2-96