

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 68269
 Permit No. _____
 Basin 065
 NOTICE OF INTENT NO. 36256

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER MIDAS JOINT VENTURE ADDRESS AT WELL LOCATION KEN SNYDER MINE NEAR MIDAS, NEVADA
 MAILING ADDRESS 6151 LAKESIDE DRIVE, SUITE 2100
RENO, NV 89511

2. LOCATION SW 1/4 SW 1/4 Sec. 22 T 39N N/S R 46E E ELKO County
 PERMIT NO. M/O1137 +082 MKR 119
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	30	30
GRAY ROCK, SEAMS OF CLAY X		30	115	85
GREEN BLACK ROCK		115	175	60
GRAY CLAY & ROCK		175	215	40
GRAY ROCK	X	215	370	155
WHITE ROCK		370	390	20
GRAY WHITE ROCK		390	520	130
See next line	X	520	660	140
GRAY WHITE ROCK WITH FRACTURES				

Placed 3/8 chip bentonite from top of gravel pack to bottom of cement seal 12' to 80'

Cemented in locking steel monument at surface

8. WELL CONSTRUCTION
 Depth Drilled 660 Feet Depth Cased 660 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7-7/8 Inches	0	20
5-1/2 Inches	20	340
5-3/8 Inches	340	660

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
3"	PVC	SCH 80	+1	660

Perforations:
 Type perforation SCREEN
 Size perforation .050

From	feet to	feet
340	640	

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 12 Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From 80 feet to 660 feet

Date started 6/1/97, 19____
 Date completed 6/4/97, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	6		1 hr.

9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Hackworth Drilling, Inc. Contractor
 Address P.O. Box 850 Contractor
Elko, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 020582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 6-10-97