WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68276
Permit No.
Basin 063

NOTICE OF INTENT NO. 36353

1. OWNER MIDAS JOINT VENTURE
MAILING ADDRESS 6151 LAKESIDE DRIVE SUITE 2100
RENO, NV 98511

ADDRESS AT WELL LOCATION
KEN SNYDER MINE NEAR MIDAS NEVADA

2. LOCATION SE 1/4 NE 1/4 Sec. 27 T 39N N/S R 46E E ELKO County
PERMIT NO. M/O 1034 ~~1092~~ (Issued by Water Resources) | MW-4 (Parcel No.) | TRACT OF LAND (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ALLUVIAL		0	8	8
BROWN SILTSTONE		8	25	17
GREEN SILTSTONE	X	25	55	30
GREEN CLAY		55	65	10
GREY, GREEN AND WHITE ROCK		65	80	15
GREEN BLACK BASALT	X	80	95	15
GREEN CLAY		95	120	25

3/8" hole plug
from 10' to 24'

Date started 5/13/97, 19__
Date completed 5/14/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1.5		1.5

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6.5" Inches		0 Feet	120 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.5"	PVC	SCH 40	+1	120

Perforations:
Type perforation SCREEN
Size perforation .050 SLOT
From 30 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 10
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 24 feet to 100 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 6-3-97