

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 68290
 Permit No. _____
 Basin 107
 36390

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER WALLACE/PERRY PROPERTY ADDRESS AT WELL LOCATION 151 RIVER VILLAGE ROAD
 MAILING ADDRESS 710 W. WILLIAMS AVENUE
FALLON, NV 89406
 2. LOCATION SE 1/4 SE 1/4 Sec. 27 T 19 N/S R 28 E CHURCHILL County
 PERMIT NO. 8-421-16 RIVER VILLAGE
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SAND		0	17	17
BROWN CLAY		17	20	3
BROWN SAND		20	43	23
GREY SAND		43	85	42
BLACK SILT/CLAY		85	120	35
BLACK SILT		120	130	10
GREY SAND		130	170	40
GREY CLAY		170	175	5
BROWN SAND	X	175	194	19

8. WELL CONSTRUCTION
 Depth Drilled 194 Feet Depth Cased 194 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 3/4 Inches 0 Feet 50 Feet
6 1/4 Inches 50 Feet 194 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	194

Perforations:
 Type perforation MACHINE SLOT
 Size perforation .080
 From 187 feet to 192 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement / 3/4" SEAL
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 22.4 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Welsco Drilling Corp. Contractor
 Address 305 E. WILLIAMS AVE. P. O. BOX 888 Contractor
FALLON, NV 89407
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
 Signed [Signature] By driller performing actual drilling on-site or contractor
 Date Aug-7-97

Date started 7/16/97, 19____
 Date completed 7/16/97, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>1 hr.</u>

RECEIVED
 97 AUG 12 AM 11:27
 STATE ENGINEERS OFFICE