


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 68295  
 Permit No. \_\_\_\_\_  
 Basin 101



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36397

1. OWNER JOHN ANGUS ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 717 RONALD WAY 717 RONALD WAY  
FALLON, NV 89406

2. LOCATION SW 1/4 SE 1/4 Sec. 27 T 19 N/S R 28 E CHURCHILL County  
 PERMIT NO. 08-451-32 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SAND		0	14	14
BROWN CLAY		14	17	3
BROWN SAND		17	30	13
GREY SAND		30	35	5
BLACK SILT/CLAY		35	50	15
GREY SAND		50	62	12
GREY CLAY		62	64	2
BROWN SAND	X	64	77	13

8. WELL CONSTRUCTION  
 Depth Drilled 77 Feet Depth Cased 77 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4	0	50
6 1/8	50	77

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	77

Perforations:  
 Type perforation MACHINE SLOT  
 Size perforation .080

From	To
70	75

Surface Seal:  Yes  No Seal Type:  
 Neat Cement *Welsco*  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 97 AUG 12 AM 11:27  
 STATE ENGINEERING OFFICE

9. WATER LEVEL  
 Static water level 9.6 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality untested

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. Contractor  
 Address 305 E. WILLIAMS AVE. P. O. BOX 888 Contractor  
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date AUG 7-97

Date started 7/22/97 19\_\_\_\_  
 Date completed 7/22/97 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr.