

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 68303  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34917

1. OWNER Bob Hammon  
 MAILING ADDRESS 5075 Alcorn Lane  
Fallon, NV 89406

ADDRESS AT WELL LOCATION  
1385 Golden Parkway, Fallon, Nv. 89406

2. LOCATION NW 1/4 NW 1/4 Sec. 19 T 19N N/S R 29E E Churchill County

PERMIT NO. 008-322-50 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	6	6
Brown Clay		6	11	5
Coarse Br. Sand		11	28	17
Gray Clay		28	33	5
Gray Sand		33	48	15
Gray C lay		48	54	6
Black Clay		54	57	3
Black Sand		57	67	10
Gray clay		67	71	4
Gray Sand		71	82	11
Brown Clay		82	84	2
Brown Coarse Sand		84	91	7

8. WELL CONSTRUCTION  
 Depth Drilled 91 Feet Depth Cased 91 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10inch Inches 0 Feet 91 Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.99	.188	0	91

Perforations:  
 Type perforation Mill Cut  
 Size perforation 1/8

From 87 feet to 91 feet *Perforation w/ worm PARSONS*  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50ft.  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 91 feet

9. WATER LEVEL  
 Static water level 14.11 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed W. Parsons  
 By driller performing actual drilling on-site or contractor  
 Date 1-3-96

Date started 11/18/96 .19  
 Date completed 11/18/96 .19

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)