WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68306 R
Permit No.
Basin 101

NOTICE OF INTENT NO. 35860

1. OWNER Bob Leegaurd
MAILING ADDRESS 1345 Hiedi Lane
Fallon, NV 89406

ADDRESS AT WELL LOCATION
1345 Hiedi Lane, Fallon, NV 89406

2. LOCATION SE 1/4 NW 1/4 Sec. 20 T 19N N/S R 28E E Churchill County
PERMIT NO. _____ Issued by Water Resources
008-173-72 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	33	33
Brown Clay		33	40	7
Brown Sand		40	75	35
Gray Clay		75	83	8
Gray Sand		83	104	21
Brown Clay		104	106	2
Brown Sand		106	117	11
Brown Clay		117	123	6
Gray Sand		123	150	27
Gray Sand		150	156	6
Gray Silt		156	160	4
Brown Clay		160	163	3
Brown Sand	X	163	180	17

RECEIVED 97 MAY 15 AM 11:23 STATE ENGINEER'S OFFICE

Date started 12/19/96 , 19__
Date completed 12/19/96 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	180 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	180

Perforations:
Type perforation Well Screen
Size perforation .030
From 175 feet to 180 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed [signature] By driller performing actual drilling on-site or contractor
Date 4-15-97