



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17353

1. OWNER CONOCO INC. 1/4 SECOR ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1515 E. TROPICANA AVE STE 200  
LAS VEGAS, NV 89119  
 2. LOCATION SE 1/4 NW 1/4 Sec. 28 T. 20 N. R. 61 E. CLARK County  
 PERMIT NO. 139-28-703-008 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE MW-6  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ASPHALT		0	0.5	0.5
POORLY GRADED SAND		0.5	1.5	1
SILTY SAND		1.5	5	3.5
SANDY CLAY		5	7	2
SANDY SILT		7	12	5
POORLY GRADED GRAVEL		12	14	2
CALICHE		14	16	2
POORLY GRADED SAND		16	26	10

8. WELL CONSTRUCTION  
 Depth Drilled 26 Feet Depth Cased 25 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 0 Feet 26 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	1.9	0.237	0	25

Perforations:  
 Type perforation FACTORY SLOT  
 Size perforation 0.020  
 From 15 feet to 25 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-11-11-13 BENTONITE  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 13 feet to 26 feet

9. WATER LEVEL  
 Static water level 16.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started July 23 1997  
 Date completed July 23 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name THOMAS HIGH (CONVERSE CONS) Contractor  
 Address 731 Pilot Rd Ste H Contractor  
LAS VEGAS NV 89119  
 Nevada contractor's license number 0034757  
 issued by the State Contractor's Board  
 Nevada driller's license number M1869  
 issued by the Division of Water Resources, the on-site driller  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 9/11/97