WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68312
Permit No.
Basin

NOTICE OF INTENT NO. 17351

1. OWNER City of Las Vegas Public Works
MAILING ADDRESS 400 E. Stewart
Las Vegas NV 89101
ADDRESS AT WELL LOCATION 1426 S. Las Vegas Blvd, Las Vegas NV

2. LOCATION NE ¼ NW ¼ Sec. 3 T 21 N/S R 61 E Clark County
PERMIT NO. (Issued by Water Resources) 162-03-210-089 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-7
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL		0	2	2
SANDY CLAY		2	4	2
CLAYEY GRAVEL		4	6	2
SANDY CLAY		6	7	1
LEAN CLAY		7	8	1
CLAYEY GRAVEL		8	11	3
GRAVELLY CLAY		11	14	3
CLAYEY GRAVEL		14	15	1

Date started July 17, 1997
Date completed July 17, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 15 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	15 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	+2.5	15

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 5 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-1'/1-3' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 15 feet

9. WATER LEVEL
Static water level 9.72 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH (CONVERSE CONS) Contractor
Address 731 Pilot Rd Ste H Contractor
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 0034757
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed By driller performing actual drilling on site or contractor
Date 9/16/97

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627