WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68349
Permit No.
Basin

NOTICE OF INTENT NO. 16794

1. OWNER MELISSA FIRPO/LARRY JENNINGS
MAILING ADDRESS
ADDRESS AT WELL LOCATION 330 S. LAFAYETTE ST.

2. LOCATION SW ¼ NW ¼ Sec. 15 T 20-S N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 35-321-34 (Parcel No.) PARCEL 2 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Surface | | 0 | 4 | 4 |
| Brown clay | | 4 | 10 | 6 |
| Gray clay | | 10 | 26 | 16 |
| Gray clay/caliche | | 26 | 54 | 28 |
| Brown clay | | 54 | 71 | 17 |
| Brown clay/caliche | | 71 | 98 | 27 |
| Brown clay | | 98 | 121 | 23 |
| Brown clay/caliche | X | 121 | 160 | 39 |
| Brown clay | | 160 | 175 | 15 |
| Brown clay/caliche | | 175 | 210 | 35 |
| Brown clay | | 210 | 225 | 15 |
| Brown clay/caliche & gravel | X | 225 | 250 | 25 |

Date started October 1, 19 97
Date completed October 2, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | 4 | ¼ |

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 Inches | | 0 Feet | 250 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | 0 | 250 |
| | | | | |
| | | | | |

Perforations:
Type perforation Torch Cut
Size perforation ¼" width 8 in. long
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 250 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name JIM PIKE WELL DRILLING, LLC. (Contractor)
Address P. O. BOX 56 (Contractor)
PAHRUMP, NV. 89041

Nevada contractor's license number issued by the State Contractor's Board 17563A

Nevada driller's license number issued by the Division of Water Resources the on-site driller 1812

Signed (By driller performing actual drilling on site or contractor)

Date OCTOBER 3, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627