

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36665

1. OWNER TIMET FACILITY HENDERSON ADDRESS AT WELL LOCATION 8100 LAKE MEAD DR HENDERSON, NV  
 MAILING ADDRESS 8100 LAKE MEAD DR HENDERSON, NV  
 2. LOCATION NE 1/4 SW 1/4 Sec. 12 T. 22 N. R. 62 E CLARK County  
 PERMIT NO. 178 12 501 007 Issued by Water Resources 178 12 001 004 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other FLSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVELLY SAND BROWN, MODERATELY SORTED		0	35.5	
GRAVELLY, MEDIUM TO COARSE SAND ABUNDANT SILT		30.5	40.5	
CLAY		40.5	43	
GRAVELLY SAND		43	44	
SILTY CLAY YELLOWISH BROWN		44	45.5	

8. WELL CONSTRUCTION  
 Depth Drilled 45.5 Feet Depth Cascd 20 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet  
0 Feet 45.5 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2.042	.237	0	20

Perforations:  
 Type perforation SCHEDULE 40  
 Size perforation .020  
 From 20 feet to 45.5 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 19  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 22 feet to 45.5 feet

9. WATER LEVEL  
 Static water level 39 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature N/A °F Quality N/A

Date started 8/19, 1997  
 Date completed 8/19, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name JOHN MAMEY Contractor  
 Address 3121 S. PARK DR TEMPE, AZ Contractor  
THE VERDE COMPANIES  
 Nevada contractor's license number issued by the State Contractor's Board 41809  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2670  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10-3-97