WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68375
Permit No.
Basin

NOTICE OF INTENT NO. 326605

1. OWNER TIMET HENDERSON FACILITY
MAILING ADDRESS 8100 LAKE MEAD DR
HENDERSON, NV

ADDRESS AT WELL LOCATION 8100 LAKE MEAD DR
HENDERSON, NV

2. LOCATION NE ¼ SW ¼ Sec. 12 T. 22 N/S R. 62 E. CLARK County
PERMIT NO. Issued by Water Resources 178 12 501 007 178 Parcel No. 001 004 Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVELY SAND WITH ABUNDANT CLAY, DARK BROWN		0	30.5	
GRAVELY MEDIUM TO COARSE SAND DARK BROWN		30.5	40	
MEDIUM TO COARSE SAND WITH A TRACE OF FINE SAND		40	45.5	
SILTY CLAY WITH A TRACE OF FINE SAND, YELLOWISH BROWN		45.5	50.5	

Date started 8/18, 1997
Date completed 8/18, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	25 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2.043	.237	0	25

Perforations:
Type perforation SCHEDULE 40
Size perforation .020
From 25 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 23.5
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 27 feet to 50 feet

9. WATER LEVEL
Static water level 39 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JOHN MANLEY
Contractor
Address 3121 S. PARK DR TEMPE, AZ
Contractor
THE VERDE CO.
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2070
Signed John Manley
By driller performing actual drilling on site or contractor
Date 10-3-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627