WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68409
Permit No.
Basin 101

NOTICE OF INTENT NO. 35605

1. OWNER Hawk Properties
MAILING ADDRESS 2161 W Williams Ave #280
Fallon, NV 89406

ADDRESS AT WELL LOCATION
4170 Hawk Drive, Fallon, NV 89406

2. LOCATION NE 1/4 NE 1/4 Sec. 28 T 19N N/S R 28E E Churchill County
PERMIT NO. _____ Issued by Water Resources | 008-281-24 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	10	10
Brown Clay		10	17	7
Brown Sand		17	37	20
Gray Clay		37	45	8
Gray Clay		45	57	12
Brown Sand	X	57	70	13

Date started 4/22/97, 19__
Date completed 4/22/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 70 Feet Depth Cased 70 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	70	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	70

Perforations:
Type perforation Mill cut
Size perforation 1/8
From 67 feet to 70 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60 feet to 70 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.
Contractor
Address P.O. Box 1265
Contractor
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 5-13-97