WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68411
Permit No.
Basin 101

NOTICE OF INTENT NO. 35867

1. OWNER SMI Joist
MAILING ADDRESS P.O. Box 2000
Hope, AR 71801-2000

ADDRESS AT WELL LOCATION
2121 Trento Lane, Fallon, NV 89406

2. LOCATION ~~SE~~ NW 1/4 SE 1/4 Sec. 14 T 19N N/S R 27E E Churchill County
PERMIT NO. 62773 (Issued by Water Resources) 007-131-23 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock
Commercial

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	15	15
Brown Clay		15	32	17
Brown Sand		32	35	3
Gray Clay		35	40	5
Gray Silt		40	50	10
Gray Sand		50	55	5
Brown Sand		55	60	5
Gray Clay		60	62	2
Gray Sand		62	73	11
Gray Clay		73	75	2
Gray Sand		75	81	6
Gray Clay		81	84	3
Brown Sand		84	93	9
Brown Clay		93	98	5
Gray Clay		98	130	32
Gray Sand		130	140	10
Gray Clay		140	143	3
Brown Sand		143	160	17
Brown Clay		160	165	5
Brown Sand	X	165	190	25

Date started 4/24/97, 19__
Date completed 4/28/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200	28	6 hr

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	190 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	14.96	.188	0	170

Perforations:
Type perforation Stainless Stell Screen
Size perforation .040
From 170 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 190 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [signature] By driller performing actual drilling on-site or contractor
Date 5-13-97