WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68416
Permit No.
Basin 101

NOTICE OF INTENT NO. 38704

1. OWNER Louie Venturacci
MAILING ADDRESS 437 Venturacci Lane
Fallon, NV 89406

ADDRESS AT WELL LOCATION
25 Deer Trail, Fallon, NV 89406

2. LOCATION SW 1/4 SE 1/4 Sec. 25 T 19N N/S R 28E E Churchill County
PERMIT NO. _____ Issued by Water Resources | 008-322-08 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	10	10
Brown Clay		10	15	5
Fine Brown Sand		15	25	10
Gray Sand		25	30	5
Gray Clay		30	45	15
Black Clay		45	55	10
Gray Sand		55	70	15
Brown Clay		70	75	5
Brown Sand		75	80	5
Brown Clay		80	85	5
Brown Sand	X	85	92	7

Date started 5/1/97, 19__
Date completed 5/1/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 92 Feet Depth Cased 92 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	92	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	92

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 87 feet to 92 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 80
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 80 feet to 92 feet

9. WATER LEVEL
Static water level 6 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons
By driller performing actual drilling on-site or contractor

Date 5/2/97