WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68932
Permit No. 63003
Basin 212

NOTICE OF INTENT NO. 16494

1. OWNER Palm Mortuary
MAILING ADDRESS 1325 No. Main Street
Las Vegas, Nv 89101

ADDRESS AT WELL LOCATION S.W.Corner of No.Jones and DeerSprings
Las Vegas, Nv

2. LOCATION NE ¼ SE ¼ Sec. 23 T. 19 N/S R. 60 E. Clark County
PERMIT NO. 63003 (Issued by Water Resources) 125-23-703-001-002-003-004 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sandy Clay | | 0 | 50' | 50' |
| Red Clay | | 51' | 98' | 47' |
| Red Sandy Clay | | 99' | 180' | 81' |
| Grey Clay | | 181' | 230' | 49' |
| Red & White Sand Stone | x | 231' | 340' | 109' |
| Tan Rock | | 341' | 380' | 39' |
| Loose Tan & White Gravel | XX | 381' | 420' | 39' |
| Tan Rock | | 421' | 530' | 109' |

Date started 9-29, 19 97
Date completed 10-20, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 530' Feet Depth Cased 530' Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 24" Inches | | 0' Feet | 50' Feet |
| 12" Inches | | 50' Feet | 530' Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14" | | | 0' | 50' |
| 8" | | | 0' | 530' |

Perforations:
Type perforation Machine
Size perforation 1/8" x 4"
From 330' feet to 530' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 120' feet to 530' feet

9. WATER LEVEL
Static water level 90' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Allen Drilling, Inc. (Contractor)
Address 4847 S. Valley View (Contractor)
Las Vegas, Nv 89103

Nevada contractor's license number issued by the State Contractor's Board 0018916
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301

Signed Fred B Allen Jr
By driller performing actual drilling on site or contractor
Date October 21, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627