

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15609

1. OWNER Dennis Mayer ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 156 Peck ID 83545 ADDRESS 1701 N. Boulder Hwy  
 2. LOCATION NW 1/4 SW 1/4 Sec. 1 T. 22 N. 62 E Clark County  
 PERMIT NO. 178-01-310-03B Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other Auger

6. LITHOLOGIC LOG MW-3

Material	Water Strata	From	To	Thickness
<u>Fill Asphalt over sand</u>		<u>0</u>	<u>1</u>	
<u>FILTY SAND</u>		<u>1</u>	<u>22</u>	
<u>SAND</u>	<u>u</u>	<u>22</u>	<u>29</u>	
<u>CALICHE</u>	<u>u</u>	<u>29</u>	<u>32</u>	
<u>SANDY GRAVEL</u>	<u>u</u>	<u>32</u>	<u>33</u>	
<u>CALICHE</u>	<u>u</u>	<u>33</u>	<u>35</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 35 Feet Depth Cased 34 Feet  
 HOLE DIAMETER (BIT SIZE)  
8 1/4 Inches From 0 Feet To 35 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>34</u>

Perforations:  
 Type perforation slotted screen  
 Size perforation .010 inch  
 From 19 feet to 34 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 18  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 18 feet to 35 feet

9. WATER LEVEL  
 Static water level 23.52 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 8/27 1997  
 Date completed 8/27 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Tim AE c/o Terracon Consultants  
 Address 4343 S. Polaris Ave  
Las Vegas NV 89103  
 Nevada contractor's license number \_\_\_\_\_ issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1944  
 Signed Thomas M. Beall  
 By driller performing actual drilling on site or contractor  
 Date 10-15-97