


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **68470**
 Permit No. _____
 Basin **162**



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **16101**

1. OWNER **KRUGER, HARVEY** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **1061 1ST STREET** **1061 1ST STREET**
PAHRUMP, NV 89048

2. LOCATION **NW** 1/4 **SW** 1/4 Sec. **14** T **20S** N/S **R 53E** E **NYE** County _____
 PERMIT NO. _____ **35-308-04** **RAYCRAFT** Subdivision Name _____
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------|--------------|------|-----|------------|
| SANDY CLAY | | 0 | 15 | 15 |
| GRAVEL & CLAY | | 15 | 120 | 105 |
| CALICHIE | | 120 | 135 | 15 |
| CLAY | | 135 | 164 | 29 |
| CALICHIE | | 164 | 172 | 8 |
| CLAY & GRAVEL | | 172 | 217 | 45 |
| CALICHIE | WB | 217 | 226 | 9 |
| CLAY | | 226 | 243 | 17 |
| CALICHIE | WB | 243 | 256 | 13 |
| CLAY | | 256 | 266 | 10 |
| GRAVEL | WB | 266 | 270 | 4 |

8. WELL CONSTRUCTION
 Depth Drilled **270** Feet Depth Cased **270** Feet

HOLE DIAMETER (BIT SIZE)
 From To
12.25 Inches **0** Feet **270** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| 8.625 | 16.94 | .188 | 0 | 270 |

Perforations:
 Type perforation **FACTORY SAW CUT**
 Size perforation **1/8 X 3**

From **250** feet to **270** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **270** feet

9. WATER LEVEL
 Static water level **60** feet below land surfac
 Artesian flow _____ G.P.M. _____ P.S.I
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started **6/3/97**, 19____
 Date completed **6/6/97**, 19____

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| | | | |
| | | | |
| | | | |

Name **Great Basin Drilling Co.** Contractor
 Address **PO BOX 4220** Contractor
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board **30880**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**

Signed *Thomas Dean*
 By driller performing actual drilling on-site or contractor
 Date **9/16/97**



OCT 16 1997