WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

#WW-22

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68478
Permit No. 59243
Basin 63

NOTICE OF INTENT NO. 36498

1. OWNER Newmont Gold, LoneTree
MAILING ADDRESS P.O. Box 388, Valmy, NV 89438

ADDRESS AT WELL LOCATION Newmont Gold, LoneTree Minesite

2. LOCATION NW ¼ SE ¼ Sec. 11 T. 34 N/S R. 42 E. Humboldt County
PERMIT NO. 59243 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
aluminum		0'	620	620
red & brown rock		620	680	60
black rock w/clay		680	900	220
red & brown rock		900	920	20
black rock w/clay		920	980	60
Valmy, quartzite		980	1520	540

RECEIVED 97 NOV 19 AM 11:07 STATE ENGINEER'S OFFICE

Date started June 28, 1997
Date completed July 29, 1997

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
730	2.1	1/2 hr.

8. WELL CONSTRUCTION
Depth Drilled 1520 Feet Depth Cased 1510 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
46 Inches		0 Feet	80 Feet
38 Inches		80 Feet	395 Feet
31 Inches		395 Feet	1520 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
40	158.69	3/8	0	80
34	134.66	3/8	0	395
24	94.61	3/8	+1	1510

Perforations:
Type perforation louvered
Size perforation 1/8
From 700 feet to 1500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60 feet to 1520 feet

9. WATER LEVEL
Static water level 421.7 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature warm °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG Exploratory Drilling (Contractor)
Address P.O. BOX 5279, Elko, NV 89802 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2000

Signed William Eddy (on site or contractor)
Date August 6, 1997

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627