

OFFICE USE ONLY
 Log No. 68477
 Permit No. _____
 Basin 03H

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31221

1. OWNER Nevada First Corp - Roy Clarno ADDRESS AT WELL LOCATION Davey Town
 MAILING ADDRESS P.O. Box 1710
Winnemucca, NV 89445 N41.177433 W117.847466
 2. LOCATION NW 1/4 NW 1/4 Sec. 17 T 38 N/S R 37 E Humboldt County
 PERMIT NO. 61889T/63035 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	3
fine Sand & gravel		3	14	11
Sandy clay		14	22	8
Coarse granite sand		22	60	38
Granit sand w/ clay		60	85	25
Sand & gravel		85	90	5
Sand		90	130	40
Sand & pea gravel		130	135	5
Granite sand w/s clay layers		135	145	10
Granite sand		145	153	8
Sandy clay		153	165	12
Granite sand		165	170	5
Sandy clay		170	175	5
Granite sand		175	250	75
Sandy clay		250	257	7
Granite sand		257	280	3
Sandy clay		280	285	5
Granite sand w/s pea gravel		285	295	10
Granite sand w/s clay stringers		295	340	45
Granite sand & pea gravel		340	400	60

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 to 400
26 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"		.250	+2	140

Perforations:
 Type perforation Double row mill slot
 Size perforation 1/8 x 2 1/2
 From 140 feet to 400 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 400 feet

9. WATER LEVEL
 Static water level 183 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
 Contractor
 Address 4675 W. Wmca. Blvd. 109-13
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4-15-96

Date started March 27, 1996
 Date completed March 28, 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
2600	350	8	