

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31088

1. OWNER Gwen Fortney ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Mail Box 458 Pilot Valley NV
MCC. weather MT 49947
 2. LOCATION SE 1/4 NW 1/4 Sec 3 T 36 N/S R 69 E 21R0 County _____
 PERMIT NO. 75-110-08 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------|--------------|------------|------------|------------|
| <u>TOP SOIL</u> | | <u>0</u> | <u>1</u> | <u>1</u> |
| <u>river boulders</u> | | <u>1</u> | <u>150</u> | <u>149</u> |
| <u>gravel sand</u> | <u>X</u> | <u>150</u> | <u>163</u> | <u>13</u> |
| <u>boulders</u> | | <u>163</u> | <u>181</u> | <u>19</u> |
| <u>gravel sand</u> | <u>X</u> | <u>181</u> | <u>187</u> | <u>7</u> |
| <u>granite</u> | | <u>187</u> | <u>200</u> | <u>13</u> |

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 19.5 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>6</u> | | <u>188</u> | | |

 Perforations:
 Type perforation face
 Size perforation _____
 From 170 feet to 180 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

Date started APR 11 18 1996
 Date completed APR 1 18 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-----------|-------------------------------|--------------|
| <u>40</u> | <u>0</u> | <u>2</u> |

9. WATER LEVEL
 Static water level 83 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AAA Drilling Contractor
 Address P.O. Box 7487 Contractor
21R0 NV
 Nevada contractor's license number issued by the State Contractor's Board 0020684
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438
 Signed Shou Bennett
 By driller performing actual drilling on site or contractor
 Date APR 11 - 20 - 96