

OFFICE USE ONLY
 Log No. 68494
 Permit No. _____
 Basin. 084

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK 31 CDA

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33895

1. OWNER KENNETH R. VERMEYS ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 5160 Jackalope Trail Road
Reno, Nevada 89510
 2. LOCATION SE NW 1/4 SWS 31 T 22N N/S R. 21 E Washoe County
 PERMIT NO. 076-180-26 Parcel No. _____
Palomino Valley Subdivision Name 31-21-7 part 2

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay w/decomposed granite		0	8	8
Weathered granite		8	27	19
Weathered granite with clay streaks		27	30	3
Weathered granite		30	54	24
Rusty brown granite		54	56	2
Gray hard granite		56	97	41
Weathered granite hard		97	131	34
Brown volcanic streak w/white quartz		131	144	13
Weathered granite hard		144	240	96
Clay streaks		240	244	4
Weathered granite		244	361	17
White granite hard		361	381	20
Weathered granite		381	444	63
Rusty weathered granite w/clay streaks		444	459	15
White granite		459	530	71
Softer weathered granite		530	664	134
Weathered broken granite X		664	685	21

8. WELL CONSTRUCTION
 Depth Drilled 685 Feet Depth Cased 685 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 685 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>685</u>

 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 640 feet to 680 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 685 feet

Date started 4-28-97 19____
 Date completed 5-02-97 19____

9. WATER LEVEL
 Static water level 511 feet below land surface
 Artesian flow _____ G.P.M. 40 P.S.I.
 Water temperature cold °F Quality clear

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date May 6, 1997