WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68515
Permit No.
Basin 69

NOTICE OF INTENT NO. 35039

1. OWNER Gordon Gault
MAILING ADDRESS 500 N. Tulley Rd. Space #1
Turlock, CA 95380

ADDRESS AT WELL LOCATION 3605 Highway 95 S.

2. LOCATION NE 1/4 SE 1/4 Sec. 15 T 38N N/S R 38E E Humboldt County
PERMIT NO. (Issued by Water Resources) 06-331-10 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	7	7
Gravel & cobbles		7	19	12
Clay w/cobbles		19	190	171
Rock & clay layers		190	285	95
Cobbles	x	285	291	6
Clay w/cobbles		291	350	59
Fractured rock w/clay & sand	x	350	400	50

RECEIVED
97 SEP 2 AM 10:48
STATE ENGINEERS OFFICE

Date started 8/28/97, 19__
Date completed 8/29/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		3.5 hrs.

8. WELL CONSTRUCTION
Depth Drilled 405 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 7/8 Inches	0 Feet	405 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	400

Perforations:
Type perforation Mill slot
Size perforation 1/8 x 3
From 280 feet to 300 feet
From 360 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 210 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 8-29-97