

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 68532
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 5122

1. OWNER AMAX GOLD INC. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 600 SOD HOUSE ROAD AMAX SLEEPER MINE
WINNEMUCCA, NV 89445

2. LOCATION NW 1/4 SE 1/4 Sec 16 T 40 S R 35 E HUMBOLDT County
 PERMIT NO. M10 411 N/A
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DISPLACED 16 LB/GAL				
CEMENT SLURRY FROM A				
OF 246 FT TO SURFACE				
*NOTE: TOP 153 FT OF WELL HAD BEEN MINED OFF BY OPEN PIT.				

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>12-1/4</u> Inches <u>0</u> Feet	<u>20</u> Feet
<u>8</u> Inches <u>20</u> Feet	<u>168</u> Feet
<u>5-1/2</u> Inches <u>168</u> Feet	<u>400</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>SCH 80</u>	<u>.375</u>	<u>0</u>	<u>168</u>
<u>2</u>	<u>SCH 80</u>	<u>SCH 80</u>	<u>+1</u>	<u>90</u>
<u>2</u>	<u>SCH 80</u>	<u>SCH 80</u>	<u>100</u>	<u>190</u>
<u>2</u>	<u>SCH 80</u>	<u>SCH 80</u>	<u>310</u>	<u>390</u>

Perforations:
 Type perforation SLOTTED
 Size perforation .010

From	feet to	feet
<u>90</u>	<u>100</u>	<u>feet</u>
<u>190</u>	<u>310</u>	<u>feet</u>
<u>390</u>	<u>400</u>	<u>feet</u>
		<u>feet</u>
		<u>feet</u>

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 400 feet

9. WATER LEVEL
 Static water level NONE feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature _____ °F Quality _____

Date started JUNE 10, 19 96
 Date completed JUNE 10, 19 96

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING
 Contractor
 Address 2286 WEST 1500 SOUTH
 Contractor
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995

Signed GUADALUPE JACOBO
 By driller performing actual drilling on site or contractor

Date 7-5-96