WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68557
Permit No.
Basin 179

NOTICE OF INTENT NO. 33055

1. OWNER Richard Stultz
MAILING ADDRESS P.O. Box 987
Ely, NV 89301

ADDRESS AT WELL LOCATION 1 mile SW of Ely

2. LOCATION NE ¼ SE ¼ Sec. 21 T. 16 N/S R. 63 E. White Pine County

PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Gravel		1	30	29
Sand & Gravel		30	90	60
Gravel		90	200	110
Sand & Gravel		200	275	75
Water Bearing Sand	x	275	280	5
Clay Sand & Gravel		280	305	25
Water Sand & Gravel	x	305	310	5
Clay Sand & Gravel		310	345	35
Water Bearing Sand & Gravel	x	345	420	75

Date started August 8, 1997
Date completed August 12, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45	138	1

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 420 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	420 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	420

Perforations:
Type perforation Factory
Size perforation 1/8" x 2½" 6 rows
From 280 feet to 420 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 420 feet

9. WATER LEVEL
Static water level 262 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold°F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
Signed Jerald P. Christiansen (By driller performing actual drilling on site or contractor)
Date August 27, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627