

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **68569**
 Permit No. _____
 Basin **044**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **36594**

1. OWNER Adobe Investment ADDRESS AT WELL LOCATION Blk A lot 2
 MAILING ADDRESS Box 3111 Twin peaks Road
Elko NV 89803

2. LOCATION NW 1/4 NW 1/4 Sec 11 T. 35 R. 54E A. Elko County
 PERMIT NO. 005-520-002 Adobe Ranches Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loam		0	2	2
CLAY		2	5	3
Brown SANDSTONE		5	30	25
Clay Light Brown		30	79	49
White SANDSTONE		79	88	9
Light tan CLAY		88	90	2
Gray CLAY		90	97	7
Brown CLAY		97	130	33
Light Cocoon color CLAY		130	167	37
Gray SANDSTONE	X	167	172	5
White SANDSTONE		172	185	13
SOFT White SANDSTONE	X	185	192	7

97 JUL 27 AM 11:20

8. WELL CONSTRUCTION
 Depth Drilled 192 Feet Depth Cased 192 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 192 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>1.88</u>	<u>72</u>	<u>192</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3/16 x 3"
 From 192 feet to 192 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 55 feet to 192 feet

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Featig Drilling Co Contractor
 Address P.O. Box 525 Contractor
Elko NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0031704
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Paul Featig
 By driller performing actual drilling on site or contractor
 Date 6-24-97

Date started 5-28 1997
 Date completed 5-30 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Approx</u>	<u>50</u>		<u>3.5</u>