WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68592
Permit No.
Basin 108

NOTICE OF INTENT NO. 27460

1. OWNER Lyon CO. School Dist. Bus yard ADDRESS AT WELL LOCATION Same
MAILING ADDRESS 25 E Goldfield Ave. NE. Yerington, NV

2. LOCATION NW ¼ SW ¼ Sec. 14 T. 13 N/S R. 25 E Lyon County
PERMIT NO. Old m/o 549-ABG (Issued by Water Resources) APN# 01-061-03 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG YBMW-18

Material	Water Strata	From	To	Thickness
on 4/16/97 I found the well to be in good condition after removing the cover, I then proceeded to drill out the 4" casing to 35'. I then pressure grouted the hole from 35' to the surface with neat cement				

Date started 4/16, 1997
Date completed 4/16, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 35' Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10" Inches	0' Feet	35' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	Sch 40	PVC	0'	35'

Perforations:
Type perforation Factory
Size perforation .020
From 15' feet to 35' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 35'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 8' feet below land surface
Artesian flow No G.P.M. N/A P.S.I.
Water temperature cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Exploration Drilling (Contractor)
Address 1635 Belford rd. (Contractor)
Reno, NV 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4/28/97

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627